

# Energy Sustainability in Queens College

Corides Gonzalez





buildings account for an average of 41% of the world's energy use.

CO<sub>2</sub> emissions from buildings are projected to grow faster than any other sector (in the USA), with emissions from commercial buildings projected to grow the fastest—1.8% a year through 2030



## Queens College CITY UNIVERSITY OF NEW YORK Campus Map

Calden Amphitheater CA  
Calden Hall CH  
Dining Hall DH  
Dining Hall DH  
Hilbert-Gins PG

Frederick Hall FH  
G Building G  
Gins Center GC  
Goldstein Theatre GT  
Harris Center HC

Building I  
Building J  
Jefferson Hall JH  
Kelly Hall KY  
King Hall KG

Kloster Hall KS  
Klipper Hall KP  
Main Building MU  
Niedermaier Hall NH  
Reynolds Hall RA

Ransom Hall RZ  
Ransom Hall RE  
Rosenbluth Library RO  
Science Building SB  
Student Union SU

Temporary I T1  
Temporary II T2  
Temporary III T3  
Parking



Queens College occupies 84 acres of land.

More than 25 buildings .



# Influencing factors on total energy use in buildings





# THE EASIEST WAY TO IMPROVE BUILDING ENERGY EFFICIENCY

Buildings account for **40%** of total national energy usage. That's more than the transportation or industrial sectors.<sup>(1)</sup>



Lighting



Heating



Cooling



Computers



Monitors




Printers




Lifts



Appliances



SPONSORED FEATURE



Changing out bulbs for better energy efficient fixtures.

CFL and LED



# close the door

against energy waste





# WE ALL PAY FOR OPEN DOORS

This is the true cost of keeping just one door open while running the air conditioning. Consider the savings.



## NEGATIVE IMPACT: ONE STORE, ONE OPEN DOOR



Wastes  
**3,850** kilowatt  
hours of  
electricity\*

Based on a 10,000 square foot business that leaves one door open for 8 hours a day, 5 days a week, from June to September, while running the air conditioner.



**\$500**

Pays about **\$500**  
more for electricity  
this summer, or  
\$125 a month\*\*



Releases more  
than **610 kg** of  
unnecessary  
carbon dioxide\*\*\*



## POSITIVE IMPACT: 1,000 STORES, CLOSED DOORS

**3.85**  
million

Saves **3.85**  
million kilowatt  
hours of  
electricity

**\$500**  
thousand

Saves  
**\$500,000**  
on summer  
electric bills



Prevents **610 tonnes**  
of CO<sub>2</sub> from being  
released (equal  
to **110** fewer cars  
or 1,400 barrels  
of oil saved)

\*Based on average usage 100,000 sq ft office space. Based on Toronto Hydro's average usage of 100,000 sq ft office space. \*\*Based on Toronto Hydro's average usage of 100,000 sq ft office space. \*\*\*Based on Toronto Hydro's average usage of 100,000 sq ft office space. \*\*Based on Toronto Hydro's average usage of 100,000 sq ft office space. \*\*\*Based on Toronto Hydro's average usage of 100,000 sq ft office space.



**TORONTO  
HYDRO**

# The Importance of data

-temperatures, CO2, Humidity  
Running motors, air flow



MEASURE CO2 TO IMPROVE VENTILATION/IAQ

TABLE 403.3  
MINIMUM VENTILATION RATES

OCCUPANCY CLASSIFICATION	PEOPLE OUTDOOR AIRFLOW RATE IN BREATHING ZONE CFM/PERSON	AREA OUTDOOR AIRFLOW RATE IN BREATHING ZONE <i>R<sub>a</sub></i> , CFM/FT <sup>2a</sup>	DEFAULT OCCUPANT DENSITY #/1000 FT <sup>2a</sup>	EXHAUST AIRFLOW RATE CFM/FT <sup>2a</sup>
<b>Correctional facilities</b>				
Cells	5	0.12	25	—
without plumbing fixtures				
with plumbing fixtures <sup>g</sup>	5	0.12	25	1.0
Dining halls	—	—	—	—
(see food and beverage service)				
Guard stations	5	0.06	15	—
Day room	5	0.06	30	—
Booking/waiting	7.5	0.06	50	—
<b>Dry cleaners, laundries</b>				
Coin-operated dry cleaner	15	—	20	—
Coin-operated laundries	7.5	0.06	20	—
Commercial dry cleaner <sup>l</sup>	30	—	30	—
Commercial laundry	25	—	10	—
Storage, pick up	7.5	0.12	30	—
<b>Education</b>				
Auditoriums	5	0.06	150	—
Corridors (see public spaces)	—	—	—	—
Media center	10	0.12	25	—
Sports locker rooms <sup>g</sup>	—	—	—	0.5
Music/theater/dance	10	0.06	35	—
Smoking lounges <sup>b</sup>	60	—	70	—
Day care (through age 4)	10	0.18	25	—
Classrooms (ages 5-8)	10	0.12	25	—
Classrooms (age 9 plus)	10	0.12	35	—
Lecture classroom	7.5	0.06	65	—
Lecture hall (fixed seats)	7.5	0.06	150	—
Art classroom	10	0.18	20	0.7
Science laboratories <sup>h</sup> , <sup>k</sup>	10	0.18	25	1.0
Wood/metal shops <sup>g</sup>	10	0.18	20	0.5
Computer lab	10	0.12	25	—
Multiuse assembly	7.5	0.06	100	—
Locker/dressing rooms <sup>g</sup>	—	—	—	0.25
<b>Food and beverage service</b>				
Bars, cocktail lounges	7.5	0.18	100	—
Cafeteria, fast food	7.5	0.18	100	—
Dining rooms	7.5	0.18	70	—
Kitchens (cooking) <sup>b</sup>	—	—	—	0.7
<b>Hospitals, nursing and convalescent homes</b>				
Autopsy rooms <sup>b</sup>	—	—	—	0.5
Medical procedure rooms	15	—	20	—
Operating rooms	30	—	20	—
Patient rooms	25	—	10	—
Physical therapy	15	—	20	—
Recovery and ICU	15	—	20	—
<b>Hotels, motels, resorts and dormitories</b>				
Multipurpose assembly	5	0.06	120	—
Bathrooms/toilet—private <sup>g</sup>	—	—	—	25/50 <sup>f</sup>
Bedroom/living room	5	0.06	10	—
Conference/meeting	5	0.06	50	—
Dormitory sleeping areas	5	0.06	20	—
Gambling casinos	7.5	0.18	120	—

Lobbies/prefunction	7.5	0.06	30	—
<b>Laboratories<sup>l</sup></b>				
Biological	—	1.0	—	1.0
Chemical	—	1.0	—	1.0
Industrial and nonteaching	—	1.0	—	1.0
Nonproduction chemical labs	—	1.0	—	1.0
<b>Offices</b>				
Conference rooms	5	0.06	50	—
Office spaces	5	0.06	5	—
Reception areas	5	0.06	30	—
Telephone/data entry	5	0.06	60	—
Main entry lobbies	5	0.06	10	—
<b>Private dwellings, single and multiple</b>				
Garages, common for multiple units <sup>b</sup>	—	—	—	0.75
Garages, separate for each dwelling <sup>b</sup>	—	—	—	100 cfm per car
Kitchens <sup>c</sup>	—	—	—	25/100 <sup>f</sup>
Living areas <sup>c,j</sup>	0.35 ACH but not less than 15 cfm/person	—	Based upon number of bedrooms. First bedroom, 2; each additional bedroom, 1	—
Toilet rooms and bathrooms <sup>g</sup>	—	—	—	20/50 <sup>f</sup>
<b>Public spaces</b>				
Corridors	—	0.06	—	—
Elevator car	—	—	—	1.0
Shower room (per shower head) <sup>f</sup>	—	—	—	50/20 <sup>f</sup>
Smoking lounges <sup>b</sup>	60	—	70	—
Toilet rooms – public <sup>g</sup>	—	—	—	50/70 <sup>e</sup>
Places of religious worship	5	0.06	120	—
Courtrooms	5	0.06	70	—
Legislative chambers	5	0.06	50	—
Libraries	5	0.12	10	—
Museums (children's)	7.5	0.12	40	—
Museums/galleries	7.5	0.06	40	—
<b>Retail stores, sales floors and showroom floors</b>				
Sales (except as below)	7.5	0.12	15	—
Dressing rooms	—	—	—	0.25
Mall common areas	7.5	0.06	40	—
Shipping and receiving	—	0.12	—	—
Smoking lounges <sup>b</sup>	60	—	70	—
Storage rooms	—	0.12	—	—
Warehouses (see storage)	—	—	—	—
<b>Specialty shops</b>				
Automotive motor-fuel dispensing stations <sup>b</sup>	—	—	—	1.5
Barber	7.5	0.06	25	0.5
Beauty and nail salons <sup>b</sup> , <sup>h</sup>	20	0.12	25	0.6
Embalming room <sup>b</sup>	—	—	—	2.0
Pet shops (animal areas) <sup>b</sup>	7.5	0.18	10	0.9
Supermarkets	7.5	0.06	8	—
<b>Sports and amusement</b>				
Disco/dance floors	20	0.06	100	—
Bowling alleys (seating areas)	10	0.12	40	—
Game arcades	7.5	0.18	20	—

Ice arenas without combustion engines	—	0.30	—	0.5
Gym, stadium, arena (play area)	—	0.30	—	—
Spectator areas	7.5	0.06	150	—
Swimming pools (pool and deck area)	—	0.48	—	—
Health club/aerobics room	20	0.06	40	—
Health club/weight room	20	0.06	10	—
<b>Storage</b>				
Repair garages, enclosed parking garages <sup>h,d</sup>	—	—	—	0.75
Warehouses	—	0.06	—	—
<b>Theaters</b>				
Auditoriums (see education)	—	—	—	—
Lobbies	5	0.06	150	—
Stages, studios	10	0.06	70	—
Ticket booths	5	0.06	60	—
<b>Transportation</b>				
Platforms	7.5	0.06	100	—
Transportation waiting	7.5	0.06	100	—
<b>Workrooms</b>				
Bank vaults/safe deposit	5	0.06	5	—
Darkrooms	—	—	—	1.0
Copy, printing rooms	5	0.06	4	0.5
Meat processing <sup>e</sup>	15	—	10	—
Pharmacy (prep. area)	5	0.18	10	—
Photo studios	5	0.12	10	—
Computer (without printing)	5	0.06	4	—

For SI: 1 cubic foot per minute = 0.0004719 m<sup>3</sup>/s, 1 ton = 908 kg, 1 cubic foot per minute per square foot = 0.00508m<sup>3</sup>/(s m<sup>2</sup>), °C = ((°F) - 32)/1.8, 1 square foot = 0.0929 m<sup>2</sup>.







[Daily](#) [Stacked](#) [Weekly](#) **[Monthly](#)** [Custom](#) [Export](#)

Show Overlay

Choose Day:

2017-05-12





# Science Building


- At any given time the Science Building represents about 20 to 25% of Queens College electrical consumption. This is because the building must bring in outdoor ventilation air to maintain indoor air quality.





## **Maintenance**

- Lifespan of equipments last longer
  - Better performance
  - Safer health conditions



The average efficiency of air conditioners unit sold tends to increase gradually over time, so replacing old units can reduce energy consumption , more comfortable and very less harmful to the environment as well as to our health.



- **Charging Stations**

*Students and faculty will always need stations to charge devices and use them.*

*Not our biggest source of energy consumption (heating/cooling bigger threat) but can make a difference.*




# What changes would you make?

**By 2050,**  
investment in wind power could help America:

- Combat climate change by cutting more than 12.3 billion tons of carbon pollution by 2050. That's equivalent to one-third of the world's annual carbon emissions.
- Create 600,000 jobs.
- Save \$108 billion in health care costs and economic damages, by removing air pollutants.



 **ENERGY**

#ActOnClimate





1. Do you have any problem with temperature management on campus? If so, please describe where on campus have you felt discomfort.
  
2. What are some changes or improvement that you would like to see on campus?
  
3. Communication is key to success! How can we improve communications for students to interact with Buildings and Grounds on campus?